



NOTES:

- 1. Make threaded and bolted 3/4" diameter tierod connections to fitting with approved ductile lugs or 90° eye bolts.
- 2. Use 5-sack cement concrete. Calcium additive not allowed.
- 3. Wrap fittings with 6-mil plastic sheet.

 Concrete must not interfere with flange bolt removal.
- 4. Tierods are not allowed between the hydrant and its gate valve.
- 5. Non-continuous circular connector rings, such as the Megalug brand are not allowed.

dwc 12-01 dwc 3-00

ZGS

AutoCAD: Thrust Block - Saddle

SADDLE BLOCKS

PAGE NO:

15

CITY OF PULLMAN ENGINEERING DIVISION

ADOPTED: April 8, 2008